


LANDLORD/HOME OWNER GAS SAFETY RECORD



WM DONNELLY AND CO. LTD

15 LAW PLACE, NERSTON, EAST KILBRIDE, GLASGOW G74 4QL
TELEPHONE: 01355 909000 FACSIMILE: 01355 909001
EMAIL: INFO@DONNELLYUK.COM WEB: WWW.DONNELLYUK.COM

I certify that I carried out inspections on the appliances detailed below

Signed:

Inspection Date: 15/07/20

INSPECTION/INSTALLATION ADDRESS

Name & Title: Mr K McKenzie

Address: Belmont Drive, East Kilbride, Glasgow

Postcode: G75 8HD Tel:

This inspection is for gas safety purposes only to comply with the Gas Safety (Installation and Use) Regulations. Flues have been inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and lining has NOT been carried out.

LANDLORD (OR AGENT) NAME & ADDRESS (if applicable)

Name & Title:

Address

Postcode Tel:

APPLIANCE DETAILS

	Location	Make	Model	Type	Flue type OF/RS/FL	Operating pressure in heat input kW/hour/Btu/h	Safety device(s) correct operation Yes/No/NA	Spillage test Pass/Fail/NA	Smoke pallet flue flow test Pass/Fail/NA	Combustion analyser reading (if applicable)	Satisfactory termination Pass/Fail/NA	Flue visual condition Pass/Fail/NA	Adequate ventilation Yes/No	Landlord's appliance Yes/No/NA	Inspected Yes/No	Appliance serviced Yes/No	Appliance Safe to use Yes/No
1	STAIRS STOVE	Worcester	GREENING 37 CDI Compact Efficiency	RS	RS	31.2	YES	NA	NA	0.0004	Pass	Pass	Yes	NA	Yes	Yes	Yes
2	FAIRWAYS STOVE	Worcester	3000i conventional	RS	RS	30	YES	NA	NA	0.0006	Pass	Pass	Yes	NA	Yes	Yes	Yes
3																	
4																	
5																	

Gas Installation Satisfactory Visual Emergency Control Accessible: Yes ☒ No ☐ Satisfactory Gas Tightness Test: Yes ☒ No ☐ Equipotential bonding satisfactory: Yes ☒ No ☐

GIVE DETAILS OF ANY FAULT

1 SYSTEM BOILER CUTS OUT DEAD RANDOMLY

DELIVER UNDER WARRANTY

RECTIFICATION WORK CARRIED OUT

WARNING- NOTICE ISSUED Yes/No/NA

WARNING TAG OR STICKER FIXED Yes/No/NA

Number of appliances tested: 1

NEXT GAS SAFETY CHECK MUST BE CARRIED OUT WITHIN 12 MONTHS

This Record is issued by: Signed: Print Name: K T Thomas Date: 15-07-2020

Received on behalf of the Landlord/Home Owner: Signed: Raymond Thomas Tenant/Agent/Landlord/Home Owner (Delete as applicable) Date: 15-07-2020