



Landlord / Owner Gas Safety Record



This inspection is for gas safety purposes only in accordance with Gas Safety (Installation and Use) Regulations. Flues were inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the Flue integrity, construction and lining has not been carried out.

Form Serial Number: FRM/C0001908

Job Address:

Name : Westwood Parish Church
Address : Belmont Drive, East Kilbride
Glasgow,
PostCode : G75 8HD Telephone : 7982837533
URN :

Contact : Westwood Parish Church

Client Landlord's Details:

Name : 24Hr Breakdown Cover - Plan 3
Address : Heating Controls , Boiler
£185.00 Inc VAT,
PostCode : Telephone :
Rented Accommodation : No No of appliance tested : 2
Visual check to ensure burner pressure + FGAS test points have been replaced? Yes

Registered Business Details: GAS SAFE NO: 57075

Gas Operative : Andrew Sanderson -
gas/heating engineer - V
Name : Wm. Donnelly & Co Ltd
Address : , 15 Law Place
, East Kilbride
PostCode : G74 4QL Telephone : 01355 909 000

Appliance Details

Location	Type	Make	Model	Landlords Appliance	Appliance Inspected	Flue Type	Operating Pressure	Device Correct Operation	Ventilation Provision Satisfactory	Visual Condition of Flue	Termination Satisfactory	Flue Performance Check	CO PPM	CO2%	CO/CO2 Ratio	Spillage Test	Appliance Serviced	Safe To Use
1	Store	Boiler	Worcester Greenstar 30cdi	No	Yes	RS	30 kW/h	Yes	Yes	Pass	Pass	N/A	13	9.1	0.000 1	N/A	Yes	Yes
2	Store	Combi	Worcester Greenstar 32cdi compact	No	Yes	RS	32 kW/h	Yes	Yes	Pass	Pass	N/A	48	8.8	0.000 5	N/A	Yes	Yes
3																		
4																		

Inspection Details

Defect Details

Appliance #	Defect Identified	Remedial Action	Warning Label Fitted	Warning Issued	Warning Note Serial No
1					
2					
3					

Smoke/ CO Alarm Details

	Location	Type	Approved Alarm Fitted	Alarm Expiry	Testing of Alarm Satisfactory	Battery/ Hard wired	Replacement Required
1							
2							

Gas installation pipework satisfactory visual inspection Yes
Emergency control accessible Yes
Satisfactory gas tightness test N/A
Equipotential bonding satisfactory Yes

This safety record is issued by: Signed

Printed name

Andrew Sanderson -
gas/heating engineer -
V

Received by: Westwood parish church

Date: 11-Dec-2024

Certificate Expiry 11/12/2025