

## **ENERGY EFFICIENCY SUMMARY**

## Westwood Church 16 Inglewood Crescent East Kilbride

Energy Consultant: Gerry Murphy CEng MEI
Prepared for: Mr. MacKenzie

Prepared for: Mr. MacKenzie

August 2010

at the site. The result of implementing the identified actions will reduce your energy establishment and to identify the main energy saving opportunities that can be made this report. The objective of the support is to investigate the energy usage of the An independent energy consultant working for the Energy Saving Trust has prepared in carbon dioxide emissions. bills and will also make a significant contribution to the national targets for a reduction

This report has identified that Westwood Church could save:

Annual Savings

£1,120

Lifetime Savings \*

£8,960

\* assumes the measures have an average lifetime of 8 years

and installation of the low-cost and capital-cost measures identified in the report This report can also be used to support an application to the Energy Saving Scotland small business loans scheme. The loan could be used to help finance the purchase

Westwood Church could apply for an interest free loan of up to:

Energy efficiency measures only

£2,750

Full cost (up to £100k)

Renewable measures only or renewable and energy efficiency measures combined

The Energy Saving Scotland smaller business service is funded by the Scottish Government and managed by the Energy Saving Trust

Westwood Church[1]

on the second of the second of

that this will save you £150 per annum. Upgrade insulation in roof space to current building standards. It is estimated

Calculations:
Based upon insulating 750 m² to current building standards
Assumptions:
U value changed from 0.4 to 0.2 W/m2K
Temperature differential = 12 Celsius
Heating period = 1400 hrs
Saving = 5,040 KWh
Saving = £150

non occupancy. It is estimated that savings of around £220 per annum could possibility of over heating the building during milder conditions and periods of season and allow for changes in seasonal temperatures, reducing the control the Church heating system, complete with inside and outside sensors It is recommended that an optimum start 7 day control system is installed to be achieved This will provide optimum start and stop times for heating during the heating

Based on existing total heating load of 74,400 KWh
Based on a saving of 10% on existing heating costs
Saving = 7,400 KWh
Saving = £220

to provide heating for the Church. It is estimated that this will result in savings consideration, it is recommended that a ground source heat pump is installed an air or ground source heat pump as an alternative heating source. For of £440 per annum. The Client has expressed an interest in exploring the possibility of deploying

Calculations:
Based on an existing heat load of 74,400 KWh
Assumed boiler efficiency of 90 %
Required Input (heat pump)=74,400x0.9/3.5=19,131
KWh
Saving =55,269 KWh
Existing Heating Cost (gas) = £2,230
Proposed Heating Cost (heat pump) = £1,790
Saving = £440
\*Assumed Coefficient of Performance (CoP) = 3.5
\*\*Based on 60% eve & week end rate & 40 % day rate

## Energy Saving Scotland - small business loans

The report has highlighted that an application for an interest free loan could be made.

This could include measures 2, 3, 4 5 & 6.

If an application was made which includes the energy efficiency measures then the value of the loan would be up to 5 times the cost savings identified.

More information can be obtained from your local business adviser.